

Australian/New Zealand Standard™

Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter



AS/NZS 3837:1998

This Joint Australian/New Zealand Standard was prepared by Joint Technical Committee FP-018, Fire Safety. It was approved on behalf of the Council of Standards Australia on 24 July 1998 and on behalf of the Council of Standards New Zealand on 17 July 1998.

This Standard was published on 5 November 1998.

The following are represented on Committee FP-018:

Australasian Fire and Emergency Service Authorities Council
Australian Building Codes Board
Australian Industry Group
AWTA Textile Testing
BRANZ
Bureau of Steel Manufacturers of Australia
CSIRO Manufacturing & Materials Technology
Department of Building and Housing (New Zealand)
Engineers Australia
Fire Protection Association Australia
Insulated Panel Council Australasia
Insurance Council of Australia Limited
Plastics and Chemicals Industries Association Incorporated
Property Council of Australia
Society of Fire Protection Engineers Australasian Chapter
Testing Interests (Australia)
Victoria University

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about joint Australian/New Zealand Standards can be found by visiting the Standards Web Shop at www.saiglobal.com.au or Standards New Zealand web site at www.standards.co.nz and looking up the relevant Standard in the on-line catalogue.

For more frequent listings or notification of revisions, amendments and withdrawals, Standards Australia and Standards New Zealand offer a number of update options. For information about these services, users should contact their respective national Standards organization.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Please address your comments to the Chief Executive of either Standards Australia or Standards New Zealand at the address shown on the back cover.

This Standard was issued in draft form for comment as DR 94340.

Australian/New Zealand Standard™

Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter

First published as AS/NZS 3837:1998.
Reissued incorporating Amendment No. 1 (June 2012).

COPYRIGHT

© Standards Australia Limited/Standards New Zealand

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Australia) or the Copyright Act 1994 (New Zealand).

Jointly published by SAI Global Limited under licence from Standards Australia Limited, GPO Box 476, Sydney, NSW 2001 and by Standards New Zealand, Private Bag 2439, Wellington 6140.

PREFACE

This Standard was prepared by the Joint Standards Australia/Standards New Zealand Committee BD/18, Fire Safety.

This Standard incorporates Amendment No. 1 (June 2012). The changes required by the Amendment are indicated in the text by a marginal bar and amendment number against the clause, note, table, figure or part thereof affected.

A1 | Amendment No. 1 was raised to address significant differences observed between group number achieved by applying empirical correlations to predict the time to flashover using AS 3837 test results and measured results achieved in AS ISO 9705.

This Standard is based on ISO 5660-1:1993, *Fire tests—Reaction to fire—Rate of heat release from building products*, except that the ISO test method excludes smoke measurement, and the test method and test apparatus are based on ASTM E 1354, *Heat and Visible Smoke Release Rates for Materials and Products Using an Oxygen Consumption Calorimeter*.

It is envisaged that in the future, applications Standards for specific materials will be prepared by appropriate committees. These applications Standards will call up this test method and will set parameters such as irradiance levels and specimen construction or any other relevant parameters.

Specifications for particular materials and products will need to state the irradiance level and specimen construction for each acceptance level.

The terms ‘normative’ and ‘informative’ have been used in this Standard to define the application of the appendix to which they apply. A ‘normative’ appendix is an integral part of a Standard, whereas an ‘informative’ appendix is only for information and guidance.

CONTENTS

	<i>Page</i>
FOREWORD.....	4
SECTION 1 SCOPE AND GENERAL	
1.1 SCOPE.....	5
1.2 PRINCIPLE OF TEST METHOD	6
1.3 REFERENCED DOCUMENTS	6
1.4 DEFINITIONS.....	7
1.5 APPLICATION TO FIRE HAZARD ASSESSMENT	7
1.6 HAZARD WARNINGS.....	7
1.7 MATHEMATICAL SYMBOLS	8
SECTION 2 APPARATUS, SPECIMENS AND TEST PROCEDURES	
2.1 TEST APPARATUS.....	10
2.2 TEST SPECIMENS	14
2.3 TEST ENVIRONMENT	16
2.4 CALIBRATION OF APPARATUS.....	16
2.5 TEST PROCEDURE	17
2.6 TEST LIMITATIONS	18
SECTION 3 CALCULATIONS AND REPORTING OF RESULTS	
3.1 CALCULATIONS.....	19
3.2 TEST REPORT.....	21
3.3 PRECISION AND BIAS	22
3.4 COMMERCIAL LITERATURE.....	24
3.4A RELEVANCE OF TEST RESULTS FOR THE CALCULATION OF GROUP NUMBER FOR CLASSIFICATION OF WALL AND CEILING LININGS IN ACCORDANCE WITH THE NCC	24
3.4B VALIDITY OF EMPIRICAL CORRELATION	24
3.5 REFERENCE IN OTHER AUSTRALIAN STANDARDS.....	25
APPENDICES	
A COMMENTARY.....	35
B REFERENCES	40
C DIAGRAM OF A TYPICAL OXYGEN CONSUMPTION CALORIMETER	41
D CALCULATION OF HEAT RELEASE WITH ADDITIONAL GAS ANALYSIS...	42
E INTERLABORATORY TRIALS	45

FOREWORD

Fire is a complex phenomenon. Its behaviour and effects depend upon a variety of factors which are inter-related in an intricate way. The behaviour of materials and products in a fire will depend on the characteristics of the particular fire, the way the materials are used and the environment in which they are exposed.

A test such as the one described in this Standard deals only with a simple representation of a particular aspect of the potential fire typified by a radiant heat source and a spark. It cannot, by itself, provide direct guidance on the behaviour or safety of a material in a fire. A test of this type may, however, be used for comparative purposes or to ensure a certain level of performance. The test basically measures heat release rates which have a bearing on fire performance generally.

The term heat release rate is defined in AS 2484.1, *Fire—Glossary of terms*, Part 1: *Fire tests*, as the amount of calorific energy released per unit time by a material during combustion under specified test conditions. It is one of the fundamental properties of fire and should almost always be taken into account in any assessment of fire hazard since it significantly affects the development of the fire.

STANDARDS AUSTRALIA/STANDARDS NEW ZEALAND

Australian/New Zealand Standard**Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter**

SECTION 1 SCOPE AND GENERAL

1.1 SCOPE**1.1.1 General**

This Standard specifies a test method for measuring the response of materials exposed to controlled levels of radiant heating with or without an external igniter. The test method is used to determine the ignitability, heat release rates, mass loss rates, effective heat of combustion, and smoke release of materials and products.

Properties are determined as follows:

- (a) Rate of heat release, by measurement of the oxygen consumption, as determined by the oxygen concentration and the flow rate in the exhaust product stream.
- (b) Effective heat of combustion from a concomitant measurement of specimen mass loss rate, in combination with the heat release rate.
- (c) Smoke release, by obscuration of light by the combustion product stream.
- (d) Ignitability, as a measurement of time from initial exposure to time of sustained flaming.

1.1.2 Objectives

The purpose of this Standard is to establish a test method for material and product evaluations, mathematical modelling, design purposes or development and research. The material may comprise specimens from an end-use product or the various components used in the end-use product.

1.1.3 Test parameters

Specimens may be exposed to heating fluxes ranging from 0 to 100 kW/m². External ignition, when used, is by electric spark. The value of the heating flux and the use of external ignition are to be as specified in the relevant material or performance standard. The normal specimen testing orientation is horizontal, independent of whether the end-use application involves a horizontal or a vertical orientation. Provisions are also made for vertical orientation testing; this is intended for exploratory or diagnostic studies only.

NOTES:

- 1 The test method does not prescribe the irradiance levels nor whether external ignition is to be used. For an insight into the development of the test method, the features of the apparatus and the use of the data, see Appendix A.
- 2 See Appendix B for a list of papers that provide additional technical background.



AS/NZS 3837:1998 Method of test for heat and smoke release rates for materials and products using an oxygen consumption calorimeter

This is a free sample only.

Purchase the full publication here:

<https://shop.standards.govt.nz/catalog/3837%3A1998%28AS%7CNZS%29/view>

Or contact Standards New Zealand using one of the following methods.

Freephone: 0800 782 632 (New Zealand)

Phone: +64 3 943 4259

Email: enquiries@standards.govt.nz